

General Maintenance Photovoltaic Arrays

BauderSOLAR F XL system



General maintenance procedures

BauderSOLAR F XL PV systems

The BauderSOLAR FXL array should be maintained by trained professionals at fixed intervals and it is recommended that an inspection is carried out annually and the modules cleaned to maintain efficiency, with electrical maintenance occurring a minimum of every three years.

All maintenance ensures that the PV array continues to perform, and that any potential problems are identified at an early stage. Any failures of the system resulting from a lack of maintenance may not be covered under the guarantee.

- Ensure safe access can be gained to the roof and that relevant Health and Safety procedures are followed.
- Ensure due care and attention is observed during inspection and maintenance of the array to prevent damage to the waterproofing system.

Inspection should comprise checking:

- Dirt on the modules, the type and levels soiling.
- Security of the anchoring system including fixings and safety pins.
- Condition of electrical connections, isolators and inverter.

Module maintenance

- Please follow module manufacturer's guidelines for specific maintenance requirements. If you are unsure regarding any aspect of maintenance, please contact the Bauder technical office to discuss requirements.

Module cleaning

Cleaning the modules can increase yield. This particularly applies to dirt caused by fallen leaves or bird droppings which can lead to partial shading. Yield decreases due to snow are negligible since these take place during the months of lowest yield.

With the passage of time, dirt and dust may accumulate on the glass surface of the module, reducing the power output of the module. We recommend regular cleaning of modules to ensure maximum power output, especially in low rain-fall areas.

- Modules should be cleaned using warm water. All types of soft foam materials, non-woven fabrics, soft sponges and soft brushes may be used.
- Avoid using tools, abrasive materials, abrasive chemicals and cleaning fluids.

Maintaining the electrical system

An annual inspection of isolators and inverters is recommended. A full electrical health check to inspect connectors etc, should be undertaken every 2-3 years. As a minimum the following should be carried out:

- Functionality of the electrical connections, isolators and inverters.
- Measurement of string voltage and currents.

Maintaining the mounting system

The PV array should only be maintained by trained professionals at fixed intervals. A minimum of every 3 years is recommended. The following points should be checked in the process:

- Security of the anchoring system.
- Integrity of the roof membrane.

Contractors currently recommended to maintain BauderSOLAR F XL systems

Maintenance can be carried out by any suitably trained contactor/operative. The following list is a non-exhaustive list of recommended contractors:

CJ Electrical

Unit 7 Edison Close,
Ipswich,
Suffolk, IP3 9GU
01473 276688
www.cjelectrical.co.uk/

PV Plus

3 Radcliffe Court,
Southampton, SO14 0PH
02380 170215
www.pv-plus.co.uk

Envirolec Smart Energy Solutions

Unit 2 Hope Lane,
Eltham,
London, SE9 3TP
020 8090 0270
www.envirolec-ses.co.uk

Ren Energy

Woodbastwick Road,
Blofield Heath,
Norwich, NR13 4RR
01603 713448
www.renenergy.co.uk

Greenbridge Renewables

27 Kendal Road,
Kirkby,
Liverpool, L33 2ED
0151 345 6739
www.gb-r.co.uk/

Solar Sense

Helios House,
Brockley Lane,
Backwell,
Bristol, BS48 4AH
01275 461800
<http://www.solarsense-uk.com>

Parker Technical Services

Head Office:
Tannochside Business Park,
4 Kilmartin Place,
Uddingston, G71 5PH
01698 381224
www.edwinjamesgroup.co.uk/businesses/ej-parker

Photon Energy

8 Windsor Square,
Silver Street,
Reading,
Berkshire,
RG1 2TH
0118 997 7470
<https://www.photonenergy.co.uk/operationandmaintenance>

Bauder Limited

70 Landseer Road, Ipswich, Suffolk, IP3 0DH
bauder.co.uk

Bauder Limited

O'Duffy Centre, Carrickmacross, Co.Monaghan
bauder.ie