

## Bauder Lightning Conductor Clips

18.05.2026



<b>Product description</b>	A lightning conductor clip riveted (carbon steel rivet) to a Bauder bituminous membrane base. Available in two colours.
<b>Application fields</b>	To be used with coated (25mm x 6mm) and un-coated (25mm x 3mm) lightning conductor tape in conjunction with Bauder bituminous waterproofing systems. <b>Must be installed by Bauder Approved Contractors.</b>
<b>Article Number</b>	GB60240135 (Charcoal Grey) GB60240130 (Brown)
<b>Website Link</b>	<a href="https://www.bauder.co.uk/products/lightning-conductor-clips">https://www.bauder.co.uk/products/lightning-conductor-clips</a>

Characteristic	Unit	Value
Length	mm	100
Width	mm	100
Thickness	mm	4.2
Central block on membrane base	mm	20 (length) x 60 (width) x 23 (depth)
Quantity	box	40
Installation centres	m	Max. 1 - please consult with lightning conductor engineer for confirmation

<b>Normative references</b>	For updated references, the latest edition of the referenced document (including any amendments) applies.
<b>Storage guidance</b>	The product should be stored dry, protected against weathering, and must not be exposed to temperatures exceeding 35°C. The products must not be exposed to a direct naked flame or other ignition sources, or to solvents or other chemicals. Ensure the product(s) are clear of buildings and any other storage areas. Where there are storage containers on site, these may be suitable for storing products.
<b>Packaging material</b>	All products are supplied loose in a cardboard box (readily recyclable).
<b>Handling/PPE</b>	All persons using the product should be fully aware of the manual handling methods as roofing materials are heavy and can cause serious injury. When using the product, installers should be provided with, and wear, suitable personal protective equipment.
<b>Disposal guidance</b>	Disposing of any waste material must be carried out in accordance with national regulations. Recommended EWC waste codes: 17 09 04 mixed construction and demolition wastes other than those mentioned in 17 09 01, 17 09 02 and 17 09 03.
<b>Further information/ documents</b>	Current documents such as brochures, installation guides, etc. can be found by visiting <a href="http://www.bauder.co.uk">www.bauder.co.uk</a>
<b>International Standards Organisation (ISO)</b>	<b>ISO 9001:2015 Quality Management</b> Certificates EN1271 (UK)  <b>ISO 14001:2015 Environmental Management Certificates</b> A10552 (UK)

### Installation Guidance:

Please refer to the Bauder Installation Guide and project specification for further guidance.  
Mark out the location for the lightning conductor tape with a chalk line.  
Heat weld the lightning conductor clip membrane to the bituminous membrane at maximum 1 metre centres or at centres detailed by the installer of the lightning protection system.  
Install the lightning conductor tape.  
Close the clip and snap tight to secure.

### MEMBRANE COLOURS



Charcoal Grey



Brown

**Safety Data Sheets are designed to provide the necessary information to recipients of substances and mixtures in the EU & UK. This product is classed as an article; therefore, this product does not have a requirement for a Safety Data Sheet.**